

WATER
CHAPTER 31.
WATER.¹

§ 31-1. Minimum size of water mains.

Sec. 31-1. Minimum size of water mains.

All water mains laid or installed in any public street, road or thoroughfare of the town, whether installed by the water company developers, owners of property to be served or otherwise, shall be at least six inches in diameter. (G.O. No. 807, § 1.)

¹ As to water supply in dance halls, see § 5-6 of this Code. As to operation, interference with, etc., fire hydrants, see § 11-4. As to water supply for swimming pool, see § 26-7.